

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION

283 m J

UNDER THE CLEAN ENVIRONMENT ACT

Re: The Clean Environment Commission and Frontier School Division, applicant, ^{GKA}

WHEREAS pursuant to the provisions of The Clean Environment Act, Frontier School Division has submitted an application to the Clean Environment Commission to prescribe limits in connection with the operation of a mechanical sewage treatment plant located at the Grand Rapids Teacherage, Lots 1, 2, 3 and 4, Plan 811 in the Local Government District of Grand Rapids, with effluent discharge into the Saskatchewan River,

AND WHEREAS no representation was made to the Clean Environment Commission by any person who is or is likely to be affected by an Order of the Commission prescribing limits in connection with the said operation,

AND WHEREAS the Clean Environment Commission considered the application to prescribe limits on the 14th day of May, 1973,


IT IS HEREBY ORDERED THAT

1. The applicant shall ensure that the said facility is constructed, maintained and operated in such a manner as to prevent contamination of groundwater,
2. The applicant shall ensure that the said facility is operated in such a manner as to minimize the release of offensive odours,
3. The applicant shall ensure that the biochemical oxygen demand loading of the said facility does not exceed eight pounds per day,
4. The applicant shall ensure that the effluent of the said facility is chlorinated to a chlorine residual of 0.5 milliliters per liter after fifteen minutes contact,
5. The applicant shall ensure that the biochemical oxygen demand of the effluent of the said facility does not exceed 30 milliliters per liter,

*Assigned to
Eng. Ops.
June 6/73*

Order No. 283

Dated at the City of Winnipeg
this 29th day of May 1973



Chairman,
Clean Environment Commission

C-b-543.1

*CC: Regional Services
Aug 17/73*