

*"BINDER COPY"*

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION  
 UNDER THE CLEAN ENVIRONMENT ACT

---

RE: THE CLEAN ENVIRONMENT COMMISSION and MANITOBA HYDRO, Applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, Manitoba Hydro filed a proposal with the Department of Consumer and Corporate Affairs and Environment in connection with the operation of a sewage treatment plant located in the SW $\frac{1}{4}$  of Section 27, Township 17, Range 11, East of the Principal Meridian in the Local Government District of Alexander, Manitoba, serving the Great Falls townsite with the disposal of effluent to the Winnipeg River;

AND WHEREAS in the absence of limits prescribed by a Regulation under the said Act, the proposal was referred to The Clean Environment Commission for the prescribing of limits;

AND WHEREAS after giving notice of the proposal, the Commission did not receive a representation from any person who is or who is likely to be affected by an order of the Commission prescribing limits in connection with the said operation;

AND WHEREAS the Commission considered the proposal on the 18th day of August, 1980;

IT IS HEREBY ORDERED THAT

1. The Applicant shall maintain and operate the said operation in such a manner that:
  - (a) there is no contamination of groundwater;
  - (b) the release of offensive odours is minimized; and
  - (c) domestic sewage only is discharged to the said sewage treatment plant.
2. The Applicant shall not permit the discharge of effluent from the said sewage treatment plant where the organic content of the effluent, as indicated by the five-day biochemical oxygen demand, is in excess of 30 milligrams per liter.
3. The Applicant shall not permit the discharge of effluent from the said sewage treatment plant where the non-filterable residue (suspended solids) content of the effluent is in excess of 30 milligrams per liter.

*Assigned  
To  
WATER POLLUTION  
CONTROL*


*September 15/80*

*[Signature]*

4. The Applicant shall not permit the discharge of effluent from the said sewage treatment plant where the faecal coliform content of the effluent, in terms of the MPN index, is in excess of 200 per 100 milliliters of sample.
  
5. The Applicant shall dispose of scum, grit, screenings, sludge or other solid waste from the said sewage treatment plant:
  - (a) in accordance with Regulations issued under the said Act in connection with the disposal of solid waste; or
  
  - (b) to a sewage treatment facility designed to accept such material and in accordance with limits prescribed for such facility under the said Act.

Order No. 896

Dated at the City of Winnipeg  
this 10th day of September, 1980.

  
Chairman,  
The Clean Environment Commission.

File: 1608.1