

Subject: R.M. of Macdonald – Community of Sanford Wastewater Stabilization Pond Expansion

File: 1921.10

The attached material can be placed in the public registries for the above stated project:

Public Comments on the Environment Act Proposal: no public comments were received during the public comment period.

Technical Advisory Committee Comments on the Environment Act Proposal:

- **Manitoba Conservation and Water Stewardship – Water Use Licensing Section, August 6, 2015**
- **Manitoba Conservation and Water Stewardship – Water Control Works and Drainage Licensing Section, August 10, 2015**
- **Manitoba Conservation and Water Stewardship – Environmental Approvals Branch, August 10, 2015**
- **Manitoba Conservation and Water Stewardship – Parks and Protected Spaces, August 10, 2015**
- **Manitoba Conservation and Water Stewardship – Wildlife and Fisheries, August 10, 2015**
- **Manitoba Infrastructure and Transportation – Highway Planning and Design Branch, August 17, 2015**
- **Office of the Fire Commissioner, August 19, 2015**
- **Manitoba Agriculture Food and Rural Development – Crops Branch, August 20, 2015**
- **Manitoba Conservation and Water Stewardship – Lands Branch, August 21, 2015**
- **Manitoba Conservation and Water Stewardship – Office of Drinking Water, August 21, 2015**
- **Manitoba Conservation and Water Stewardship – Air Quality Branch, August 21, 2015**
- **Manitoba Conservation and Water Stewardship - Environmental Compliance and Enforcement, September 25, 2016**

From: [Matthews, Rob \(CWS\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: RE: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10
Date: August-06-15 11:14:15 AM

No concerns.

Rob Matthews, WULS, CWS.

From: [Roberts, Dan \(CWS\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10
Date: August-10-15 9:10:22 AM
Attachments: [Application for Licence to Construct Water Control Works.pdf](#)

Any water control works (drains, culverts, dykes, dams, etc.) associated with this project will require licensing under the *Water Rights Act* – an application is attached for the proponent’s convenience. Any inquiries in this regard may be directed to the local *Water Resource Officer*. Their contact information may be found at:

http://www.gov.mb.ca/conservation/waterstewardship/licensing/pdf/officer_areas_of_focus_30mar2015.pdf

Sincerely,

Dan Roberts

Water Resource Officer
Water Control Works and Drainage Licensing Section
Conservation and Water Stewardship
Box 6000, Building #1180, 75 - 7th Avenue,
Gimli, MB R0C 1B0

From: [Kasur, Dean \(CWS\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: RE: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10
Date: August-10-15 1:24:29 PM

Looks ok. They need to ensure that the treated soil meets industrial guidelines indicated in this document to allow to be used as cover at the WDG.

http://www.gov.mb.ca/conservation/envyprograms/contams/pdf/guidlines/criteria_acceptance_contaminated_soil_licensed_grounds_e.pdf

Dean Kasur

Manager, Environment Section
Environmental Approvals
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, MB R3H 0W4
Phone: **204-470-5682**
Fax: **204-948-2338**
e-mail: Dean.Kasur@gov.mb.ca

To report an Environmental Emergency please call our **24/7 Emergency Response Line (204)944-4888**
Toll Free in Manitoba 1-855-944-4888

From: Dey, Asit (CWS)
Sent: August-06-15 11:16 AM
To: Kasur, Dean (CWS)
Subject: FW: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10

Dean,

This is the project that I was referring to. Please review it and let me know if you have any comment.

Thanks,

Regards,

Asit Dey
T: (204) 945-2614 F: (204) 945-5229
Email: asit.dey@gov.mb.ca

From: [+WPG1212 - Parks Circulars \(CWS\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: RE: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10
Date: August-10-15 2:21:19 PM

Parks and Protected Spaces Branch has reviewed the proposal submitted pursuant to the *Environment Act* Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10. The Branch has no comments or concerns to offer as it does not affect any provincial park, park reserve, ecological reserve, areas of special interest or proposed protected areas.

From: [Kiss, Brian \(CWS\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: RE: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10
Date: August-10-15 3:12:26 PM

No wildlife related concerns.

-Brian Kiss



Infrastructure and Transportation

Highway Planning and Design Branch
Environmental Services Section
1420 – 215 Garry St., Winnipeg, MB R3C 3P3
T (204) 619-4359 F (204) 945-0593

August 17, 2015

Tracey Braun, M. Sc.
Director, Environmental Approvals Branch
Manitoba Conservation and Water Stewardship
123 Main St., Suite 160
Winnipeg, MB R3C 1A5

RE: R.M. of Macdonald – Sanford WW Stabilization Pond Expansion
Client File No. 1921.10

Dear Ms. Braun:

MIT has reviewed the proposal under the *Environment Act* noted above and we do not have any concern with the proposed development.

Thank you very much for providing us the opportunity to review the proposal.

Sincerely,

Ryan Coulter, M. Sc., P. Eng.
Manager of Environmental Services

From: [Kubish, Cheryl \(OFC\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: RE: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10
Date: August-19-15 8:44:32 AM

The Office of the Fire Commission has no concerns or comments.

Cheryl Kubish
Administrative Assistant
Office of the Fire Commissioner
508-401 York Avenue
Winnipeg MB R3C 0P8
Phone: 945-3328
Fax: 948-2089

From: [Wilson, Brian \(MAFRD\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: RE: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10
Date: August-20-15 2:41:00 PM

No concerns.

Brian Wilson
Brian.Wilson@gov.mb.ca

From: [+WPG1212 - Conservation Circulars \(CWS\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: Request for EAP review/comment - Sanford Waste Stabilization Pond - WWTL - File: 1921.10
Date: August-21-15 8:25:35 AM

Hello Asit,

Good morning

Lands Branch – MCWS has no comments/concerns as regards Sanford Waste Stabilization Pond - WWTL - File: 1921.10. No Crown Lands are impacted by the development activities outlined in the proposal.

Thank you for the opportunity to review

Winifred Frias
Crown Land Programs Administrator
Lands Branch
Manitoba Conservation and Water Stewardship
200 Saulteaux Crescent, Box 25
Winnipeg, Manitoba R3J 3W3 CANADA

From: [Stibbard, James \(CWS\)](#)
To: [Dey, Asit \(CWS\)](#)
Subject: RE: 1921.10 RM of MacDonald Sanford WW Lagoon EXpansion EAP Review
Date: August-21-15 9:06:15 AM

Dr. Dey,

As there are no public or semi-public water systems downstream of this lagoon which use the La Salle River as a raw water source, Office of Drinking Water has no concerns with this EAP or the proposed development.

If you have any questions, please call.

Regards,

James Stibbard P. Eng.
Approvals Engineer
Office of Drinking Water
1007 Century Street
Winnipeg MB R3H 0W4

DATE: 21 August, 2015

TO: Asit Dey
Environmental Approvals
Conservation and Water Stewardship
160-123 Main Street, Winnipeg

FROM: Muntaseer Ibn Azkar
Climate Change and Air Quality
Conservation and Water Stewardship
160-123 Main Street, Winnipeg

SUBJECT: Sanford Waste Stabilization Pond Expansion (File 1912.10)

Air Quality Section has reviewed the above proposal and provides the following comments:

- The proposal is not expected to have a significant impact on air quality.
- The odour clause is suggested to be included in the License.

Memo

To: Asit Dey

From: Alvin Dyck

CC:

Date: 2015-09-25

Re: Environment Act Proposal – Sanford Waste Stabilization Pond - WWTL - File: 1921.10

Environmental Compliance and Enforcement Branch has reviewed this application and has the following comments:

- A recent inspection indicates that there may be a former truck haul area at the lagoon. The Environment Act Proposal indicates that this lagoon does not receive truck-hauled sewage or wastewater. If this is the case the former truck haul station should be removed or assessed.
- It is acknowledged within the Environment Act Proposal that a petroleum-impacted soil treatment facility was located on the land at which the expanded lagoon cell will be constructed. Plans are to remove existing petroleum-impacted soils and use as fill or cover at the adjacent Sanford waste disposal ground.

A request for approval to dispose of this soil at the Sanford waste disposal ground was made by Stantec on behalf of the Rural Municipality of Macdonald on April 10, 2015. It was accompanied by a Stantec report entitled *Soil Sampling Program at the Sanford Soil Treatment Facility, Rural Municipality of Macdonald, Manitoba* which indicated that the petroleum content of some soils exceeded Manitoba's *Criteria for Acceptance at a Waste Disposal Ground*. Therefore, the Department issued the attached May 15, 2015 letter stating that further soil treatment would be required. The proponent is requested to provide further information and/or rationale that would justify use of the subject soil at the waste disposal ground.

Manitoba Conservation and Water Stewardship concurs that stripping 600 mm of soil within the former soil treatment cell area will likely ensure that petroleum-impacted soils have been removed prior to construction of the new lagoon cell. The Department requests that a site decommissioning report including confirmatory soil sampling be submitted for approval in accordance with section 7.0 of Manitoba's *Treatment and Disposal of Petroleum Contaminated Soil* guideline.