

**File: 5624.00**

February 7, 2017

Shannon Johnson  
Manitoba Hydro  
820 Taylor Avenue  
Winnipeg, MB R3M 3T1

Dear Ms. Johnson:

**Re: Lake Winnipeg East System Improvement Project – Environment Act Licence  
No. 3120**

This is in regard to your letter dated January 20, 2017 requesting approval to refuel equipment at a location within 100 metres from a waterbody.

The Environmental Approvals Branch is processing this request as a minor alteration to Environment Act Licence No. 3120, pursuant to clause 14(2)(b) of *The Environment Act*. In accordance with Section 14(2) of *The Environment Act*, I hereby grant approval to Manitoba Hydro to implement the proposed alteration, as described in the request, and subject to the following conditions:

1. The containment berm must be constructed of material(s) suitable for the containment and recovery of spills;
2. The fuel tank must be Transport Canada certified;
3. There must be adequate lighting during fueling; and
4. No fueling shall occur at within 100 metres of a waterbody in association with this Development after February 28, 2017.

If you have any questions regarding this matter, please contact Ms. Elise Dagdick of this office at [Elise.Dagdick@gov.mb.ca](mailto:Elise.Dagdick@gov.mb.ca).

Yours sincerely,



Tracey Braun, M.Sc.  
Director

c: Don Labossiere, Director, Environmental Compliance and Enforcement Branch  
Donna Smiley, Provincial Manager, Environmental Compliance and Enforcement Branch  
Public Registries