

Dey, Asit (SD)

From: Dey, Asit (SD)
Sent: June-04-19 10:03 AM
To: 'Peter Grieger'; 'mike@glenway.net'
Cc: Burland Ross, Siobhan (SD); Davies, Scott (SD); Markwart, Larry (SD); Hawryliuk, Yvonne (CON)
Subject: 2019-06-04_authorization.to.use.cell3_glenway.colony_file5634.00(eal3276)

Hello Peter and Micheal,

Receipt of the soil liner test results submitted by Mr. Peter Grieger, P.Eng., of South-Man Engineering on May 31, 2019 for the recently constructed expansion cell no. 3 of the Glenway Colony's wastewater treatment lagoon (lagoon) is acknowledged.

The test results indicate that the soil liner of cell no. 3 of the lagoon meets the requirements of Clause 18 of Environment Act Licence No. 3276 (Licence) regarding hydraulic conductivity. Authorization to operate this cell of the lagoon is provided pursuant to Clause 22 of the Licence.

If you have any questions concerning this approval, please contact me at (204) 945-2614 or at asit.dey@gov.mb.ca .

Thanks,

Regards,

Asit Dey
Environmental Approvals Branch
Municipal and Industrial Section
T: (204) 945-2614 F: (204) 945-5229
Email: asit.dey@gov.mb.ca

From: Peter Grieger [mailto:peter@southmaneng.com]
Sent: May-31-19 1:38 PM
To: Dey, Asit (SD) <Asit.Dey@gov.mb.ca>; mike@glenway.net
Subject: Hydraulic Conductivity Results

Hi Asit,

Attached are results for hydraulic conductivity tests for Glenway.

Please contact me if you need any additional information.

Thank you
Peter Grieger
South-Man Engineering