

**Webb, Bruce (CWS)**

---

**To:** Steele, Tania (CWS)  
**Subject:** RM of Wallace - Kola Wastewater Treatment Lagoon File: 5731.00

The attached material can be placed in the public registries for the above project:

**Additional Information request** – no additional information required.

**Public Comments:** No public comments received.

**Technical Advisory Committee Comments:** (11 pages)

- Manitoba Conservation and Water Stewardship – Environmental Programs and Strategies Branch, Air Quality Section, September 11, 2014
- Manitoba Conservation and Water Stewardship – Lands Branch, September 30, 2014
- Manitoba Conservation and Water Stewardship – Parks and Protected Spaces Branch, September 22, 2014
- Manitoba Conservation and Water Stewardship – Wildlife Branch, September 9, 2014
- Manitoba Conservation and Water Stewardship – Water Science and Management Branch, Water Quality Management Section, October 3, 2014
- Manitoba Conservation and Water Stewardship – Water Use Licensing Section, September 8, 2014
- Manitoba Conservation and Water Stewardship – Water Control Works and Drainage Licensing Section, September 4, 2014
- Manitoba Infrastructure and Transportation – Highway Planning and Design Branch, Environmental Services Section, September 24, 2014
- Manitoba Municipal Government – Community and Regional Planning Branch, October 6, 2014
- Office of the Fire Commissioner, September 11, 2014
- Canadian Environmental Assessment Agency, September 10, 2014

Bruce.

DATE: 11 September, 2014

TO: Bruce Webb *BW*  
Environmental Approvals  
Conservation and Water  
Stewardship  
160-123 Main Street, Winnipeg

FROM: Muntaseer Ibn Azkar  
Air Quality-Environmental Programs  
& Strategies  
Conservation and Water Stewardship  
1007 Century Street, Winnipeg

**SUBJECT: RM of Wallace – Wastewater Treatment Lagoon (File. 5731.00)**

Air Quality Section has reviewed the above proposal and provides the following comments:

- The proposal is not expected to have a significant impact on air quality provided that the measures cited are implemented.
- The odour clause is suggested to be included in the License.

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

---

**From:** +WPG1212 - Conservation\_Circulars (CWS)

**Sent:** September-30-14 1:32 PM

**To:** Webb, Bruce (CWS) *BW*

**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

Hi Bruce,

Good afternoon.

The Lands Branch has no concerns as there are no Crown lands impacted by the proposal.

Thank you for the opportunity to review.

Kind regards

**Winifred Frias**

Crown Land Programs Administrator

Lands Branch

Manitoba Conservation and Water Stewardship

200 Saulteaux Crescent, Box 25

Winnipeg, Manitoba R3J 3W3 CANADA

Phone: (204) 945-4524

Facsimile: (204) 948-2197

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

---

**From:** Kelly, Jason (CWS)

**Sent:** September-22-14 8:51 AM

**To:** Webb, Bruce (CWS)

**Subject:** RE: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

Parks and Protected Spaces Branch has reviewed the proposal submitted pursuant to the *Environment Act* for Request for review/comment - EAP RM of Wallace WWTL File: 5731.00. The Branch has no comments or concerns to offer as it does not affect any provincial parks, park reserves, ecological reserves, areas of special interest or proposed protected areas.

Jason Kelly, M.N.R.M.  
Ecological Reserves and Protected Areas Specialist  
Parks and Protected Spaces Branch  
Conservation and Water Stewardship  
Box 53, 200 Sauteaux Cres  
Winnipeg, MB R3J 3W3

Phone: 204-945-4148

Cell:

Fax: 204-945-0012

Email: [Jason.Kelly@gov.mb.ca](mailto:Jason.Kelly@gov.mb.ca)

**Webb, Bruce (CWS)**

---

**From:** Boissonneault, Caroline (CWS)  
**Sent:** September-09-14 1:20 PM  
**To:** Webb, Bruce (CWS) *BR*  
**Subject:** Emailing: Request for reviewcomment - EAP RM of Wallace WWTL File 5731.00.msg  
**Attachments:** Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

Hello Bruce,  
Wildlife Branch has reviewed the proposal and has no further comments to add.

Thank you.  
Caroline Boissonneault  
Conservation and Water Stewardship  
Wildlife Branch  
Tel.: 204-945-6810  
[Caroline.boissonneault@gov.mb.ca](mailto:Caroline.boissonneault@gov.mb.ca)

Your message is ready to be sent with the following file or link attachments:

Request for reviewcomment - EAP RM of Wallace WWTL File 5731.00.msg

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.



DATE: October 3, 2014

TO: Bruce Webb <sup>BW</sup>  
Environmental Approvals Branch  
160-123 Main Street, Winnipeg,  
MB  
R3C 1A5

FROM: Joy Kennedy  
Water Quality Management Section  
Water Science and Management Branch  
160-123 Main Street, Winnipeg, MB  
R3C 1A5

TELEPHONE: 945-7908

FACSIMILE: 948-2357

EMAIL: joy.kennedy@gov.mb.ca

**SUBJECT: ENVIRONMENT ACT PROPOSAL FILE: 5731.00 RM OF WALLACE  
WASTEWATER TREATMENT LAGOON UPGRADE**

---

- The following effluent standards should be in place for the RM of Wallace wastewater treatment facility as per the *Manitoba Water Quality Standards, Objectives and Guidelines Regulation* (196/2011).
  - BOD<sub>5</sub> 25 mg/L
  - TSS 25 mg/L
  - Fecal Coliforms 200 MPN / 100mL
  - Total phosphorus <1 mg/L or demonstrated nutrient reduction strategy.
- The *Manitoba Water Quality Standards, Objectives and Guidelines Regulation* requires new or expanding wastewater treatment facilities to meet a <1 mg/L phosphorus limit or implement a nutrient reduction strategy. The effluent standards of the RM of Wallace wastewater treatment facility should not allow discharge where the total phosphorus content of the effluent is in excess of 1 milligram per litre or demonstrate the effectiveness of trickle discharge to < 1 mg/L phosphorus limit at the outlet of where the Proponent has control of the discharge water.
- The Water Quality Management Section is concerned with any discharges that have the potential to impact the aquatic environment and/or restrict present and future uses of the water. Therefore it is recommended that the license require the proponent to actively participate in any future watershed based management study, plan/or nutrient reduction program, approved by the Director.

Joy Kennedy

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

---

**From:** Matthews, Rob (CWS)

**Sent:** September-08-14 12:58 PM

**To:** Webb, Bruce (CWS)

**Subject:** RE: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

No concerns.

Rob Matthews, Manager, Water Use Licensing Section, Manitoba Conservation and Water Stewardship.

**Webb, Bruce (CWS)**

---

**From:** Roberts, Dan (CWS)  
**Sent:** September-04-14 10:32 AM  
**To:** Webb, Bruce (CWS) BW  
**Subject:** Request for review/comment - EAP RM of Wallace WWTL File: 5731.00  
**Attachments:** Drainage Licence Application.pdf

Any water control works (drains, culverts, dykes, dams, etc.) associated with this project will require licensing under the *Water Rights Act* – an application is attached for the proponent's convenience. Any inquiries in this regard may be directed to the local *Water Resource Officer*. Their contact information may be found at:

[http://www.gov.mb.ca/conservation/waterstewardship/licensing/pdf/areas\\_of\\_focus\\_jan\\_23\\_12.pdf](http://www.gov.mb.ca/conservation/waterstewardship/licensing/pdf/areas_of_focus_jan_23_12.pdf)

Sincerely,

**Dan Roberts**

Water Resource Officer  
Water Control Works and Drainage Licensing Section  
Conservation and Water Stewardship  
Box 6000, Building #1180, 75 - 7th Avenue,  
Gimli, MB R0C 1B0  
Cell: (204) 281-2122





Infrastructure and Transportation  
Highway Planning and Design Branch  
Environmental Services Section  
1420 - 215 Garry St., Winnipeg, MB R3C 3P3  
T (204) 619-4359 F (204) 945-0523

September 24, 2014

*BW*  
Tracey Braun, M. Sc.  
Director, Environmental Approvals Branch  
Manitoba Conservation and Water Stewardship  
123 Main St., Suite 160  
Winnipeg, MB R3C 1A5

RE: R.M. of Wallace - WWTL  
Client File No. 5731.00

Dear Ms. Braun:

MIT has reviewed the proposal under the Environment Act noted above and we have the following comments:

- MIT South Western Regional Operations is not prepared to allow the discharge of effluent into the highway right-of-way as outlined in the proposal. Please note that Departmental authority to regulate and enter into agreements regarding drainage works on highway rights-of-way, on lands owned and administered by the Department and within controlled areas adjacent to Provincial Roads is established under Sections 4(1), 5(1), 8(1), 8(3), 14 and 36(a, b, & d) of the Highways and Transportation Act.
- Under the Highways and Transportation Act, any new, modified or relocated access connection onto a PR will require a permit from Manitoba Infrastructure and Transportation - Highway Planning and Design for PR's. A permit may also be required for:
  - Any construction (above or below ground level) within 38.1 m (125 ft) from the edge of the right-of-way along PR 257;
  - Any plantings within 15.2 m (50 ft) from the edge of the right of way of PR 257; or
  - Discharge of water or other liquid materials into the ditch on PR 257.

For any questions regarding the comments above, please contact Ashley Beck at (204) 728-7000 or at [Ashley.Beck@gov.mb.ca](mailto:Ashley.Beck@gov.mb.ca).

Thank you very much for providing us the opportunity to review the proposal.

Sincerely,

Ryan Coulter, M. Sc., P. Eng.  
Manager of Environmental Services

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

---

**From:** Sumner, Kevan (MMG)  
**Sent:** October-06-14 1:50 PM *BW*  
**To:** Webb, Bruce (CWS)  
**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

I have reviewed the following Proposal on behalf of the Brandon office of Community and Regional Planning. I apologize for this response being sent after the deadline. We have identified no concerns with the Proposal. We do note that sewage disposal lagoons are a conditional use in the "AG80" zone, under the R.M. of Wallace Zoning By-law No. 1866. If a conditional use has not yet been obtained for the proposed lagoon, the proponents should contact the R.M. of Wallace to make the necessary application.

Kevan W. Sumner  
Regional Manager  
Community and Regional Planning - Brandon Regional Office  
Ph: (204) 726-6271  
Email: [kevan.sumner@gov.mb.ca](mailto:kevan.sumner@gov.mb.ca)

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

---

**From:** Kubish, Cheryl (OFC)

**Sent:** September-11-14 2:12 PM

**To:** Webb, Bruce (CWS)

**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

The Office of the Fire Commissioner has no comments or concerns at this time.

Cheryl Kubish  
Administrative Assistant  
Office of the Fire Commissioner  
508-401 York Avenue  
Winnipeg MB R3C 0P8  
Phone: 945-3328  
Fax: 948-2089

E-Mail address: [Cheryl.Kubish@gov.mb.ca](mailto:Cheryl.Kubish@gov.mb.ca)

**Webb, Bruce (CWS)**

---

**Subject:** FW: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

---

**From:** Sigurdson,Shauna [CEAA] [mailto:Shauna.Sigurdson@ceaa-acee.gc.ca]

**Sent:** September-10-14 11:42 AM

**To:** Webb, Bruce (CWS)

**Subject:** RE: Request for review/comment - EAP RM of Wallace WWTL File: 5731.00

Hello Bruce

This is not a designated project under CEAA 2012, so the Agency will not be involved further.

Shauna