



**Conservation and Water Stewardship**

Environmental Stewardship Division  
Environmental Approvals Branch  
123 Main Street, Suite 160, Winnipeg, Manitoba R3C 1A5  
T 204 945-7086 F 204 945-5229  
[www.gov.mb.ca/conservation/eal](http://www.gov.mb.ca/conservation/eal)

**Client File: 5745.00**

December 30, 2014

Mr. Andres Mormul  
Environmental Health Officer  
First Nations and Inuit Health Branch – Manitoba Region  
Health Canada  
300-391 York Avenue  
Winnipeg MB R3C 4W1

Dear Mr. Mormul:

**RE: Health Canada – Biomedical Waste Transfer Facility – DGHTA Licence Proposal - FILE: 5745.00**

I have completed the review of all Technical Advisory Committee (TAC) comments received during the initial environmental assessment of the proposed Health Canada – Biomedical Waste Transfer Facility project.

I am herewith enclosing the following comment received from the Technical Advisory Committee (TAC) for your information:

(1) Office of the Fire Commissioner -E mail dated December 1, 2014

If you have any questions in this regard, please contact the undersigned at (204) 945-7086 or e mail at [raj.rathamano@gov.mb.ca](mailto:raj.rathamano@gov.mb.ca).

Yours truly,

*Original signed by Raj Rathamano*  
*Raj Rathamano*  
Hazardous Waste Program Specialist/  
Environment Officer

Encl/.

**C: Public Registry**

Attachment

**Health Canada – Biomedical Waste Transfer Facility – DGHTA Licence Proposal - FILE: 5745.00**

**Comments received from the Technical Advisory Committee (TAC) for information**

(1) **Office of the Fire Commissioner, December 1, 2014**

**From:** Kubish, Cheryl (OFC)  
**Sent:** December-01-14 9:20 AM  
**To:** Rathamano, Raj (CWS)  
**Subject:** FW: DGHT Application for review & comment - Health Canada Bio-Waste - DGHT File: 5745.00

The Office of the Fire Commissioner recommends that the proponent obtain a new Occupancy permit for this portion of the building where the waste /storage area in the basement, as this an office building. The contact is the City of Winnipeg Building Code authority at 83-30 Fort Ave. Also, the proponent shall submit an updated Fire Safety Plan for review /acceptance by the Winnipeg Fire Department.

Cheryl Kubish  
Administrative Assistant  
Office of the Fire Commissioner  
508-401 York Avenue  
Winnipeg MB R3C 0P8  
Phone: 945-3328  
Fax: 948-2089

E-Mail address: [Cheryl.Kubish@gov.mb.ca](mailto:Cheryl.Kubish@gov.mb.ca)